

Spill Summary Report for NRC Report #1057305

Report Date: 9/14/2022

Report Time: 4:04 PM EDT

Region II Hotline Log Entry Information

Data ID: 1443274

Date Of Report: 8/16/2013

NRC #: 1057305

State #: 1305336

ERNS #:

Material Type: Oil

Receiver: Rothouse

Material / Amount:

DI ELECTRIC FLUID (800 GALLON(S));

Location:

Street:

City: NEW YORK

County: NEW YORK (MANHATTAN)

State: NY

Latitude:

Longitude:

Source of Pollution:

CON EDISON

Water Body:

State Or EPA Responded:

Initial EPA Action:

Contacted NY DEC/ Mr. White for f/u. Also spoke with Con Edison (Bill Wainright) See action report.

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0642611

Date: 8/16/2013	Time: 13:23	
Duty Officer/Responder Name: Rothouse	NRC Report #: 1057305	Hotline Log DataID: 1443274
Action Information		
Description: Called RP (Con Edison/) in an effort to determine if any storm drain or water way has been impacted. At this point in time they are just searching for the leak, but the individual I spoke to (Bill Wainright) indicated that the feeder line does run under the Harlem River. The individual handling this situation is a Mr. David Duke (tel. No. 212-580-8383). He should have more detailed information hopefully later today.		
Follup-Up:		
Person Contacted		
Name: Bill Wainright Organization: Con Ed. Phone #: 212-580-6763		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1057305

INCIDENT DESCRIPTION

*Report taken by: RSG2992 RSG2992 at 12:47 on 16-AUG-13

Incident Type: FIXED

Incident Cause: UNKNOWN

Affected Area:

The incident occurred on 16-AUG-13 at 12:30 local time.

Affected Medium: UNKNOWN

REPORTING PARTY

Name: WAINRIGHT

Organization: CON EDISON

Address: 128 WEST END AVE
NEW YORK, NY 10023

ALTERNATE Phone: (212) 5806763

INCIDENT LOCATION

WEST 49TH ST SUB STATION County: NEW YORK (MANHATTAN)

637 WEST 49TH ST

City: NEW YORK State: NY

RELEASED MATERIAL(S)

CHRIS Code: OTH Official Material Name: OTHER OIL

Also Known As: DI ELECTRIC FLUID

Qty Released: 800 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER IS REPORTING THAT A 800 GALLONS OF DI ELECTRIC FLUID IS MISSING FROM A

FEEDER. THE ESTIMATED LEAK RATE IS 10 GALLONS PER HOUR. THE EXACT LOCATION OF THE LEAK IS UNKNOWN AT THIS TIME.

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: OTHER
Power Generating Facility: NO
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

Hours Direction of

Closure Type Description of Closure Closed Closure
Air: N

Road: N Major Art_N

Waterway: N

Track: N

Passengers Transferred: NO
Environmental Impact: NO
Media Interest: NONE Community Impact due to Material:

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: WAINRIGHT
Organization: CON EDISON
Address: 128 WEST END AVE
 NEW YORK, NY 10023
ALTERNATE Phone: (212)5806763
Type of Organization: PUBLIC UTILITY

REMEDIAL ACTIONS

CREWS ARE SEARCHING THE LINE TO FIND THE SOURCE OF THE LEAK.
Release Secured: UNKNOWN
Release Rate: 10 GALLON(S) per HOUR
Estimated Release Duration:

WEATHER

Weather: UNKNOWN, ♦ F

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)
16-AUG-13 12:53 (609)7240008
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
16-AUG-13 12:53 (202)3661863
U.S. EPA II (MAIN OFFICE)
(732)3214370
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
16-AUG-13 12:53 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)
16-AUG-13 12:53 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
16-AUG-13 12:53 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
16-AUG-13 12:53 (206)5264911
NATIONAL RESPONSE CENTER HQ (AUTOMATIC REPORTS)

16-AUG-13 12:53 (202)2671136
BUREAU TOXIC SUBSTANCE (MAIN OFFICE)
16-AUG-13 12:53 (518)4027810
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
16-AUG-13 12:53 (518)4577362
SECTOR NEW YORK (COMMAND CENTER)
(718)3544356
NJ DEP POC: DUTY OFFICER (MAIN OFFICE)
16-AUG-13 12:53 (609)5844551
USCG DISTRICT 1 (COMMAND CENTER)
16-AUG-13 12:53 (617)2238555

ADDITIONAL INFORMATION

*** END INCIDENT REPORT # 1057305 ***
Report any problems or Fax number changes by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>